

LOCATION 3489 Fieldstone Dr. CITY Gastonia
BETWEEN Rock Creek Ct STREET & Cal-de-Ste STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	116'	7-5-01		
MAIN TO PROP LINE	3/4"	P	45'			
PROP LINE TO BLDG	3/4"	P	71'			

ENTERS 3489 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 198' NE of center of Rock Creek Ct

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.
MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 3 FT 0 IN LOCATION 20' SE of center of Fieldstone Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 0548307

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	