

LOCATION 3515 FIELDSTONE DR CITY GASTONIA  
BETWEEN ROCK CREEK CT STREET & MISSY RIDGE CT STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>114</u>	<u>10.2.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>38</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>76</u>			

ENTERS 3515 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION N. side of 3515

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GL  
MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 2500  
DEPTH 3 FT IN LOCATION E. side of FIELDSTONE DR

"A" P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	