

LOCATION 3547 Fieldstone Dr. CITY GASTONIA

BETWEEN Misty Ridge Cr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>106'</u>	<u>5-18-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>66'</u>			

ENTERS 3547 BRANCHED INTO

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 31' N. of curb of Misty Ridge Cr

PRESSURE TEST @ 100 PSI FOR 44 HRS BY SLK

MAIN-SIZE 3" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 20' SE. of curb of Fieldstone Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 2 LR # 412184

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

