

LOCATION 3586 Fieldstone Dr. CITY GASTONIA
BETWEEN Misty Ridge STREET & Kendrick Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>115'</u>	<u>9-26-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>105'</u>			

ENTERS 3586 BRANCHED INTO 0
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 258' N of C of Kendrick Rd.


PRESSURE TEST 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 6 IN LOCATION 20' E of C of Fieldstone Dr.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red	S	Riser Plastic
New Service		
P/S Pipeline Lead - White	E	
Existing Main		