

LOCATION 211 E. 5th St

CITY GastoniaBETWEEN Union RdSTREET & Broad St

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|-------------------------------|---------|
| MAIN TO BLDG. | 3/4 | P | 2' | 1-31-94 | tiel over 48' of 3/4 C/w Ser. | |
| MAIN TO PROP. LINE | | | | | to Ext 9" P Main | |
| PROP. LINE TO BLDG. | | | | | | |

ENTERS: 211

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE

P.S.I.


INCHES W.C.

LOCATION 17' S. of C of
5th St.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JPMAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING P. TOTAL ANODES 1# 1 17# L.R. #

REMARKS: wire tied off at Main



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>R</u> | .900 |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY