

LOCATION 212 E 5th

CITY Gastonia

BETWEEN Broad

STREET & Union Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	37'		Tied over 60' of Ext	
MAIN TO PROP. LINE				2-1-94	3/4 Plastic with 37' of	
PROP. LINE TO BLDG.					New 3/4 Plastic	

ENTERS: 212 E 5th.

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION 15' S of 6th

298' W of 6th Union Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 4 Ft. 0 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	