


LOCATION 214 E 5th AveCITY CantonBETWEEN BroadSTREET & Union Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>2 1/4</u>	<u>P</u>	<u>40'</u>		<u>Tied over 32' of Ext 3 1/4" gas</u>	
MAIN TO PROP. LINE			<u>Teflon Pipe</u>		<u>to 4" plastic main</u>	
PROP. LINE TO BLDG.					<u>2-1-94</u>	

ENTERS: 214BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 15' S of 5th231' W of 5th AvePRESSURE TEST: @ 100 psi For 64 Hrs. By EPMAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993DEPTH: 4 Ft. 0 In. LOCATION \_\_\_\_\_"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. # \_\_\_\_\_REMARKS: Tie in wire tied off at main

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1.0</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY