

LOCATION 216 E. 5th CITY GASTONIA
BETWEEN BROAD STREET & UNION Rd STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|------------|---------------|------------------------------------------------------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>plastic</u> | <u>18'</u> | | <u>Tied over EXT 5' to 4"</u> | |
| MAIN TO PROP. LINE | | | | <u>2-2-94</u> | <u>plastic main</u> | |
| PROP. LINE TO BLDG. | | | | | <u>21' EXT 3/4 C/W</u> <u>33' EXT 3/4 plastic</u> | |

ENTERS: 216 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 14 Hrs. By EP


MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # _____

REMARKS:

Tracer wire tied off at main



| Test Station | | |
|--------------------------------------------|--------------------------|------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> <u>Riser</u> | <u>1.0</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY