

LOCATION 1806 W. 5th AVE CITY GASTONIA

BETWEEN Hampton STREET & SHERMAN STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>10 8'</u>	<u>10-17-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>73'</u>			

ENTERS: 1806 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 141' N.E. of center of SHERMAN St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By H

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1963

DEPTH: 3 Ft. 0 In. LOCATION 11' SE of center of W 5th

"A" P/S READING 1.4 TOTAL ANODES 1# 017 # 6 L.R. # 580872

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY