

LOCATION 2579 Firethorn Ct. CITY Boston, MA

BETWEEN TRA Olive Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>578"</u>	<u>D</u>	<u>46'</u>	<u>8-23-01</u>		
MAIN TO PROP LINE	<u>578"</u>	<u>P</u>	<u>3'</u>			
PROP LINE TO BLDG	<u>578"</u>	<u>P</u>	<u>43'</u>			

ENTERS 2579 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 97' NE. of cont. of TRA Olive Dr


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.C.

MAIN-SIZE 2' C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION 19' SE of cont. of Firethorn Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 649874

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	