


LOCATION	2610 Firethorn Ct			CITY	GASTONIA	
BETWEEN	Tea Olive Dr			STREET &	NANDINA Ct.	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	15'	11/17/00		
MAIN TO PROP LINE			2'			
PROP LINE TO BLDG			10'			
ENTERS	2610 Firethorn Ct			BRANCHED INTO	2602 Firethorn Ct	
TAP SIZE	3/4	PRESSURE	60 PSI	3/4 INCHES WC	LOCATION	95' East of
	Center of Firethorn Ct.					
PRESSURE TEST @	100 PSI	FOR	1/4 HRS	BY	IQ Cook	
MAIN-SIZE	3/4	C I	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED
					✓	2000
DEPTH	2 FT	4 IN	LOCATION	105' South of Center of		
	Tea Olive Dr.					
"A" P/S READING				TOTAL ANODES 1#	17#	LR #
REMARKS	Ran New 3/4 plastic service					
	Split with service next door					



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead White Existing Main	E	