

LOCATION 2626 Fire thorn CITY Gastonia  
BETWEEN Ten Olive Dr. STREET & Nandina Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>63'</u>	<u>1-5-2001</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>4'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>54'</u>	<u>"</u>		

ENTERS 2626 Fire thorn BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 315' south


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY O.R. of center of Ten Olive Dr.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 19' East of center of Fire thorn Ct.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 0004319

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>175m</u>