


LOCATION 2626 Fire thorn CITY Gastonia
 BETWEEN Fire Thorn STREET & TEA OLIVE STREET
~~INSTALL~~ Relocate

	SIZE	TYPE	LENGTH	INSTALL	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plas</u>	<u>15'</u>	<u>012501</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plas</u>	<u>0</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plas</u>	<u>15'</u>	<u>012501</u>		

ENTERS 2626 Fire thorn BRANCHED INTO None
 TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES WC LOCATION _____

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RJ/M
 MAIN-SIZE 3/4 C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED _____
 DEPTH 2 FT 0 IN LOCATION _____

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ LR # _____
 REMARKS Relocated service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	