

COPY

LOCATION 2728 Forest Ave Ct. CITY Baltimore
 BETWEEN NANDINA Ct. STREET & End of Caldesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>90'</u>	<u>9-11-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>Plastic</u>	<u>3'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>85'</u>			


ENTERS 2728 BRANCHED INTO 0
 TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W/C LOCATION 447' S of C of NANDINA Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 39' E of C of Firethorn Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.58</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1.58</u>