

LOCATION 2736 Fire Thorne C.T CITY GASTON, GA  
BETWEEN Nan Dina STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>F</u>	<u>111'</u>	<u>10-24-01</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>"</u>	<u>7'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>"</u>	<u>104'</u>			

ENTERS 2736 Fire Thorne BRANCHED INTO  
TAP SIZE 3/4 PRESSURE 60 PSI INCHES W/C LOCATION N side of 2736

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SM  
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED  
DEPTH 3 FT 0 IN LOCATION E side of Fire Thorne

"A" P/S READING N/A TOTAL ANODES 1# 17# LR #

REMARKS

