

LOCATION 2326 Firmin Ct. CITY GASTONIA

BETWEEN Belinda Ct STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	117'	1-21-98		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	80'			

ENTERS: 2326 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 347' N. of center of

Belinda Ct


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hufschulte

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN. LOCATION 18' W of center of Firmin Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 6549

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY