

LOCATION 2023 Flint Ln. CITY Gaston  
BETWEEN Payson St. STREET & Lane no. 3 St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	122'	7-30-02		
MAIN TO PROP LINE	3/4"	P	8'	"		
PROP LINE TO BLDG	3/4"	P	114'	"		

ENTERS 2023 BRANCHED INTO 0

TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 170' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woodley of center of Lane no. 3 St.

MAIN-SIZE 21" C I      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 13' south of center of Flint Ln.

"A" P/S READING N/A TOTAL ANODES 1# 2 17# 0 LR # 00208382

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	1.5