

LOCATION 1501 Florida St CITY Gastonia
BETWEEN Townsend STREET & Carolina STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>		<u>✓</u>	
MAIN TO PROP LINE	<u>4</u>	<u>4</u>	<u>5'</u>		<u>2-</u>	<u>5 - 98</u>
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>55'</u>			

ENTERS: 1501 BRANCHED INTO: -
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SE
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY