

LOCATION 1609 Florida St. CITY Castroville

BETWEEN Carolina Ave. STREET & 19th St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>2'</u>	<u>2-7-98</u>	<u>Tie over</u>	<u>80' 3/4"</u>
MAIN TO PROP. LINE					<u>Existing</u>	<u>Plastic Surge</u>
PROP. LINE TO BLDG.						

ENTERS: 1609 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 194' N. of center of 19th St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hultsch

MAIN-SIZE 2" C I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH. 3 FT. 0 IN LOCATION 12' W. of center of Florida St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY