


LOCATION 1609 Florida St.CITY GastoniaBETWEEN 19th St.STREET & Carolina Ave

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>115'</u>	<u>7-31-96</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>80'</u>			

ENTERS: 1609BRANCHED INTO: —TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 14' E. of CapFlorida StPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP-RKMAIN-SIZE 1 1/2 C.I. \_\_\_\_\_ BARE STEEL ☒ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1958DEPTH: 2 FT. 6 IN. LOCATION \_\_\_\_\_"A" P/S READING 60TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # \_\_\_\_\_

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY