


LOCATION 1610 Florida StCITY GastoniaBETWEEN CapdripSTREET & 19th

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>26</u>	<u>Tied-over</u>	<u>74' of 3/4</u>	<u>PLASTIC</u>
MAIN TO PROP. LINE				<u>to New</u>	<u>2" PLASTIC</u>	<u>main</u>
PROP. LINE TO BLDG.					<u>2-7-98</u>	

ENTERS: 1610BRANCHED INTO: ✓TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____PRESSURE TEST: @ 100 PSI FOR 4/4 HRS BY SSMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN LOCATION _____"A" P/S READING PLASTIC TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY