

LOCATION 1615 Florida St CITY Gastonia

BETWEEN Carolina Ave STREET & 19th St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	99'		2-7-98	
MAIN TO PROP. LINE	3/4"	P	10'		Retired	97' Sig. off
PROP. LINE TO BLDG.	3/4"	P	89'			Service

ENTERS: 1615 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 52' N. of center of 19th St


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN. LOCATION 12' W. of center of Florida St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 11689

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY