

LOCATION 1804 & 1808 Florida St CITY Oakton
BETWEEN Dend End STREET & 20th St STREET.

	SIZE	TYPE	1804 LENGTH	1808	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>67'</u>	<u>20'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>	<u>0'</u>			<u>3-14-58</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>37'</u>	<u>20'</u>			

ENTERS: 1804 BRANCHED INTO: 1808
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 3 FT. 6 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# ✓ L.R. # _____

REMARKS: _____

Test Station			ENG. DEPT. USE ONLY	
Reading & Location	Lead	Volts		
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>		
P/S Pipeline Lead - White Existing Main	<u>E</u>			

