

LOCATION 1810 & 1812 Florida St CITY Canton  
BETWEEN 20th STREET & Dead End STREET

	SIZE	TYPE	1810 LENGTH	1812	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>B</u>	<u>60'</u>	<u>22'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>B</u>	<u>30'</u>	<u>1'</u>			<u>3-14-58</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>30'</u>	<u>21'</u>			

ENTERS: 1810 BRANCHED INTO: 1812  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 3 FT. 6 IN. LOCATION

"A" P/S READING P TOTAL ANODES 1# 17 L.R. # \_\_\_\_\_

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY