


LOCATION 1814 FloridaCITY ConroeBETWEEN 20th STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <u>Q</u>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>		<u>3-14-98</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>26'</u>			

ENTERS: 1814 BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION _____PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EPMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998DEPTH: 3 FT 6 IN LOCATION _____"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY