

LOCATION 702 Flave St. CITY Gastonia

BETWEEN Stagecoach Rd. STREET & Martha St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	99'	1-29-99		
MAIN TO PROP LINE	3/4"	P	30'			
PROP LINE TO BLDG.	3/4"	P	69'			

ENTERS: 702 BRANCHED INTO

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 577' E. of center of

Stagecoach Rd.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. HURST

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED

DEPTH: 3 FT 0 IN LOCATION 10' SE of center of Flave St

"A" P/S READING .5 TOTAL ANODES 1# 0 17# 8 L.R. # 53672

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY