

LOCATION 804 + 806 Floyd Ln CITY Gastonia
BETWEEN Seventh STREET & Hooper STREET

	SIZE	TYPE	804 LENGTH	806	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	12	5	7-21-97		
MAIN TO PROP LINE	1"	11	12	5			
PROP LINE TO BLDG.	1"	11	12	5			

ENTERS: 804 BRANCHED INTO: 806

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 112' S of C of Seventh


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BC

MAIN-SIZE 2" C I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. IN. LOCATION 177' E of C of Floyd

"A" P/S READING plastic TOTAL ANODES 1# - 17# - I.R. # 0468315

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY