

LOCATION 827 Floyd Ln. CITY Boston
BETWEEN Kaylor Ct STREET & W. 7th Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>90'</u>	<u>4-2-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>25'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>65'</u>			

ENTERS 827 BRANCHED INTO
TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 401' S. of center of W 7th Ave

PRESSURE TEST @ 160 PSI FOR 14 HRS BY S.H.
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1960
DEPTH 3 FT 0 IN LOCATION 12' E. of center of Floyd Ln.

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 LR # 223705

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	