


LOCATION 838 Floyd St. CITY Cincinnati
 BETWEEN Seventh ave STREET & Hay/12 Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>60'</u>	<u>6-19-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>6'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>54'</u>	<u>"</u>		

 ENTERS 838 BRANCHED INTO 0
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 461' west of center
Seventh ave.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Wood
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1960
 DEPTH 3' FT 0" IN LOCATION 13' south of center of Floyd Ave.
 "A" P/S READING 1.15 TOTAL ANODES 1# _____ 17# _____ LR # 00157984
 REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u> <u>ris</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	