

LOCATION 851 Floyd Ln. CITY Gastonia  
BETWEEN W. 7th Ave. STREET & Kaylor Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>94'</u>	<u>4-02-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>32'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>62'</u>			

ENTERS 851 Floyd Ln. BRANCHED INTO Ø  
TAP SIZE 3/8" PRESSURE 60 PSI \_\_\_\_\_ INCHES W/C LOCATION 505' North


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. R. center of Kaylor Ct.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1960

DEPTH 3' FT 0" IN LOCATION 12' East center of Floyd Ln.

"A" P/S READING 1.2 TOTAL ANODES 1# Ø 17# Ø LR # 00223742

REMARKS New 3/4" P. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>