

LOCATION 963 Floyd Ln. CITY GASTON

BETWEEN Kaylar Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	578"	P	78'	3-15-02		
MAIN TO PROP LINE	578"	P	10'			
PROP LINE TO BLDG	578"	P	68'			

ENTERS 862 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 359' N. of curb of Kaylar Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1960

DEPTH 3 FT 0 IN LOCATION 15' E. of curb of Floyd Ln.

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 LR # A0121871

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	