

LOCATION 863 Floyd Ln. CITY CANTONIA  
BETWEEN Kaylor Ct STREET & W. 7th Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>91'</u>	<u>2-6-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>61'</u>			

ENTERS 863 BRANCHED INTO  
TAP SIZE 42 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 332' S. of center of Kaylor Ct


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH 3 FT 0 IN LOCATION 14' E of center of Floyd Ln.

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR # 76315

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	