

LOCATION 868 Floyd Ln. CITY GASTON

BETWEEN Kaylon Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	27'	3.15-02		
MAIN TO PROP LINE	5/8"	P	10'			
PROP LINE TO BLDG	5/8"	P	17'			

ENTERS 868 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 71' E. of center of Floyd Ln


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.

MAIN SIZE 5/8" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 2002

DEPTH 2 FT 0 IN LOCATION 365' N. of center of Kaylon Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # A0121865

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	