

LOCATION 903 Floyd Ln CITY Gastonia
BETWEEN Hooper STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	Plastic	81'	8/4/97		
MAIN TO PROP. LINE	3/4'		32'			
PROP. LINE TO BLDG.	3/4'		49'			

ENTERS: 903 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N side of 903

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1960
DEPTH: 3 FT 0 IN LOCATION West side of Floyd Ln

"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 505644

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY