

LOCATION 935 Floyd Lane CITY GASTONIA
BETWEEN Hooper STREET & 7th Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>95'</u>	<u>12-17-97</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>30'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>65'</u>			

ENTERS: 935 BRANCHED INTO: —

TAP SIZE: 3/8 PRESSURE 60 PSI — INCHES W C LOCATION


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY SE

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1960

DEPTH: 3 FT 0 IN LOCATION

"A" P/S READING 114 TOTAL ANODES 1# — 17# — L.R. # 856650

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY