

LOCATION 943 Floyd Ln CITY Gastonia
BETWEEN Hooper STREET & KAY LOR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>74'</u>	<u>10-28-99</u>		
MAIN TO PROP LINE	<u>1/2</u>	<u>11</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>1/2</u>	<u>11</u>	<u>68'</u>			

ENTERS 943 BRANCHED INTO —
TAP SIZE 1/2 PRESSURE — PSI — INCHES W C LOCATION 15' N. of COJ


PRESSURE TEST 100 PSI FOR 1/4 HRS BY CLP Hooper

MAIN SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC — YEAR INSTALLED 1970

DEPTH 2 FT 6 IN LOCATION —

"A" P/S READING 1.30 TOTAL ANODES 1 # — 17# — LR # —

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>I</u>	