

LOCATION 902 Fonda Dr. CITY Gastonia
BETWEEN Alton Dr STREET & Florida Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>70'</u>	<u>4-10-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>85'</u>			

ENTERS 902 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 5' W. of center of Alton Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 9 IN LOCATION 13' N. of center of Fonda Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 316814

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

