

LOCATION 3004 Forbes CITY Gastonia
BETWEEN Todd Reece Lk STREET & LITTLE MTR Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>165</u>	<u>10-16-97</u>		
MAIN TO PROP. LINE	<u>1</u>	<u>1</u>	<u>45</u>			
PROP. LINE TO BLDG.	<u>1</u>	<u>1</u>	<u>120</u>			

ENTERS: 3004 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 13' W. of C of
Forbes Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GP

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>PR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY