

LOCATION 3016 Forbes Rd. CITY GASTONIA
BETWEEN Little mtw Rd STREET & Todd Reese Ln STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>124'</u>	<u>12-12-97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>112'</u>			

ENTERS: 3016 BRANCHED INTO: ✓
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION _____

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY SE
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 4 FT. 0 IN LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — L.R. # 845876

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY