

LOCATION 3036 Forbes Rd CITY Gastonia
BETWEEN Todd Reese Ln STREET & Little mtn Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>158'</u>	<u>10-13-97</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>"</u>	<u>118'</u>			

ENTERS: 3036 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE — PSI — INCHES W.C. LOCATION 12' w. of cap
Forbes Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 4" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION —

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>5 R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY