

LOCATION 605 Forest Dr. CITY EASTONIA
BETWEEN Union Rd. STREET & Fern Forest Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56'</u>	<u>11-13-56</u>	<u>5-30-94</u>	<u>5-30-94</u>
MAIN TO PROP. LINE					<u>3/4" BARE 56'</u>	<u>7/4</u>
PROP. LINE TO BLDG.					<u>Service</u>	

ENTERS: 605 BRANCHED INTO: 607
TAP SIZE: 3/4 Straight Tee PRESSURE 60 P.S.I. INCHES W.C. LOCATION 284' E of Co of Union Rd.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
~~MAIN~~ SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994
DEPTH: 2 Ft. 0 In. LOCATION 72' S of Co of Fern Forest Dr.

"A" P/S READING P TOTAL ANODES 1* 17* L.R. #

REMARKS: Retired & Renewed Service. Retired



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY