

LOCATION 611 Forest Dr. CITY Ashtonia  
BETWEEN Union Rd. STREET & Tanglewood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>85'</u>		<u>1-16-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>83'</u>			

ENTERS. SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 211' from @ of Tanglewood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.H.T.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION Southside of forest Dr.

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY