

LOCATION 700 FOREST DR. CITY GAST.

BETWEEN TANGLE WOOD DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>135'</u>		<u>1-17-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>46'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>89'</u>			

ENTERS: SAME BRANCHED INTO

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 102' from C of

TANGLE WOOD DR.


PRESSURE TEST: @ 100 PSI FOR 1/2 HRS BY D.H.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN. LOCATION south side of forest Dr.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY