

LOCATION 709 Forest Dr. CITY GAST.

BETWEEN Tanglewood Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>65'</u>		<u>1-17-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>63'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 131' From @ of

Tanglewood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4" HRS BY D.H.f

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN. LOCATION Southside of Forest Dr.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY