

LOCATION 911 FOREST DR. CITY GAST.

BETWEEN CRESTWOOD AVE. STREET & TANGLEWOOD DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>44'</u>		<u>2-3-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>41'</u>			

ENTERS: SAME BRANCHED INTO: 903 FOREST DR.

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 117' From N of

CRESTWOOD AVE.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY ASH

MAIN-SIZE 2" C I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN LOCATION EASTSIDE OF FOREST DR.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY