

LOCATION 3205 Forest Creek Ct. CITY Bastonia A  
BETWEEN Strong box h.n. STREET & Hunting Wood St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>51'</u>	<u>3-13-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>6'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>	<u>"</u>		

ENTERS 3205 Forest Creek Ct. BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 58' West


PRESSURE TEST @ 60 PSI FOR 1/4 HRS BY D.R. Ø center of Forest Creek Ct.

MAIN-SIZE 4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3' FT 4" IN LOCATION 18' south of center of Forest Creek Ct.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 00177702

REMARKS New 3/4" P. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>