

LOCATION 3212 Forest Creek Ct. CITY Craster, IA  
BETWEEN Strong Box Ln. STREET & Huntingwood Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	74'	4-11-03		
MAIN TO PROP LINE	5/8"	P	7'	"		
PROP LINE TO BLDG	5/8"	P	67'	"		

ENTERS 3212 BRANCHED INTO 0  
TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 178' south


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody  
of center of Strong Box Ln.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 19' East of center of Forest Creek Ct.

"A" P/S READING 1714 TOTAL ANODES 1# 0 17# 0 LR # 00080755

REMARKS New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	plastic
P/S Pipeline Lead White Existing Main	E	rise