

LOCATION 3236 Forest Creek Ct CITY Crustonia
BETWEEN Strong Box Ln STREET & Huntingwood Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	63'	4-11-03		
MAIN TO PROP LINE	5/8"	P	7'	"		
PROP LINE TO BLDG	5/8"	P	56'	"		

ENTERS 3236 BRANCHED INTO Δ

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 33' north of

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
center of Huntingwood Ct.

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 20' East of center of Forest Creek Ct.

"A" P/S READING 121A TOTAL ANODES 1# 6 17# 0 LR # C0081119

REMARKS New Plastic Service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead White Existing Main	E	copper

