

LOCATION 3244 Forest Creek Ct. CITY Gastonia
BETWEEN Huntingwood Ct. STREET & End of Caldesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>60'</u>	<u>9-10-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>Plastic</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>Plastic</u>	<u>55'</u>			


ENTERS 3244 BRANCHED INTO 0
TAP-SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 38' E of C of Huntingwood Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 4 FT 0 IN LOCATION 20' N of C of Forest Creek Ct.

"A" P/S READING Plastic w/in TOTAL ANODES 1# 17# LR #

REMARKS.



Test Station		
Reading & Location	Lead	Volts*
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>