

LOCATION 3261 Forest Creek Ct. CITY Gastonia
BETWEEN Huntingwood Ct. STREET & Strong Box Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>70'</u>	<u>5-09-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>62'</u>	<u>"</u>		

ENTERS 3261 BRANCHED INTO 0
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W/C LOCATION 204 East of


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Di. Woods center of Huntingwood Ct.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 36' south of center of Forest Creek Ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 L R # DD 340173

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>service</u>